ADDENDUM # 1 PW-2025-03

PART 1 GENERAL

The following changes are effective immediately and shall be incorporated into the Contract Documents.

PART 2 INFORMATION/CLARIFICATION

2.1 CLARIFICATION

.1 NA

PART 3 SPECIFICATIONS

3.1 SYSTEM #1 – TERTIARY TREATMENT 46 73 00

- .1 Part 2 Products
 - .1 **Amend 2.1.5** All housings, structural components, return water collection tank, driven impeller and shaft, filtration media, piping, manifolds, nozzles, valve bodies, ducts, bases, covers, anchors, and fasteners must be a minimum of Type 316 or 316L Stainless Steel, **if applicable**.

PART 4 QUESTIONS AND ANSWERS

4.1

- .1 **Q** Can you provide additional wastewater influent and effluent characteristics?
 - A Please see attached performance results for 2022, 2023, and 2024.
- .2 **Q** Is there plans for a sludge recycle from the settle cell back to the aerated lagoon?

A – If this is a requirement for your system to work, it should be identified in your proposal as a condition to meet the effluent requirements.

.3 **Q** – What process upgrades are being incorporated into the treatment train ahead of the tertiary filtration system?

A – The mechanical aeration system will be replaced with diffused aeration in the aeration cell as well as Cell C which will flow into the new Submerged Attached Growth Reactor SAGR system. The SAGR is a clean gravel bed with evenly distributed wastewater flow across the width of the cell, and a horizontal collection chamber at the end of the treatment zone. Linear[™] aeration throughout the floor of the SAGR provides aerobic conditions that are required

Township of North Glengarry		Project No. 22039
Alexandria Sewage Works Expansion	ADDENDUM # 1	
Equipment Preselection	PW-2025-03	Page 2 of 2

for nitrification. The gravel bed is covered with a layer of wood chips for insulation. Anticipated water quality at the various stages of treatment is as follows:

		Lagoon Influent	SAGR Influent	System Effluent Compliance	System Effluent Objective
Design Flow	m ³ /day	6,500			
Max Day Peak Flow*	m ³ /day	19,500			
cBOD₅	mg/l	110	<25	<10	<10
TSS	mg/l	100	<25	<15	<15***
TKN	mg/l	18			
Total Ammonia	mg/l			<2/4**	<1/2**
Unionized Ammonia	mg/l				****

* Assuming that a lagoon effluent control structure will be in place to limit the peak day flow.

** Summer/Winter

*** After tertiary filtration

*** Meets WSER toxicity requirements

Coagulant addition to the lagoons is used to reduce the total phosphorus in the effluent. This practice will continue after the upgrades. There will be no additional coagulant addition between the lagoons and the SAGR system. Please refer to attached historic performance tables for total phosphorus results. It is not expected that the SAGR system will have an impact on the total phosphorus concentration leaving the lagoons and entering the tertiary treatment system.

.4 **Q** – Part 1 (page 2) item 1.2.2 Tertiary treatment controls are to integrate with control ancillary equipment required for the treatment operation including but not limited to the flocculation tank mixer (as required), coagulant system (if required) polymer system (if required), washing system, filter discharge and backwash pumping. This integration shall be accomplished through data communication on standard Ethernet between the filter PLC and the main plant PLC/SCADA system.

A – The proponents shall identify in their submission what is the minimum preliminary treatment required between the SAGR system and the proposed tertiary treatment system in their submission (i.e. coagulant addition, polymer addition, rapid mix, flocculation, etc.).

.5 **Q** - It is our understanding that following the planned upgrades, the upstream treatment process will be design in a way that minor quantities of algae or algae-related solids may be present in the influent to the tertiary filters. Please confirm whether this understanding aligns with the specifications?

A – The Township does not currently monitor the algae content in the effluent from the lagoons. The project does include the construction of a SAGR system which will provide rough filtration through a gravel bed prior to tertiary treatment.

END OF SECTION

NORTH GLENGARRY WATER WORKS

WASTEWATER TREATMENT WORKS PERFORMANCE RESULTS

Municipality: North Glengarry

NORTH GLENGARRY NORD

Project: Alexandria STP

Year: 2024

Receiving Stream: Delisle River

Description: 1 Pumping Station, 1 Aerated Cell, 3 Facultative Cells

tative Cells Design Capacity: 3,237 m³/day

Continuous Discharge with Phosphorous Removal

		Flows		Bioche	mical O ₂ D	emand	Suspended Solids Phosphorus			Phosphorus Average Raw TP Average Effluent TP (mg/L) (mg/L) 1.12 0.20 1.99 0.17 1.73 0.19 1.04 0.16 3.66 0.09 1.15 0.10		
MONTH	Total Flows	Average Daily Flow	Maximum Daily Flow	Average Raw CBOD₅	Average Effluent CBOD₅	Percent Removal	Average Raw SS	Average Effluent SS	Percent Removal	Average Raw TP	Average Effluent TP	Percent Removal
	(m ³)	(m³)	(m³)	(mg/L)	(mg/L)	(%)	(mg/L)	(mg/L)	(%)	(mg/L)	(mg/L)	(%)
Jan	101,902	3,287	5,909	83.0	4.3	94.8	132.0	5.0	96.2	4.65	0.11	97.7
Feb	113,273	3,906	6,995	31.0	8.0	74.2	106.0	8.3	92.2	1.12	0.20	82.4
Mar	156,619	5,052	10,623	89.0	6.0	93.3	226.0	6.5	97.1	1.99	0.17	91.3
Apr	168,382	5,613	9,050	71.0	3.0	95.8	154.0	3.8	97.5	1.73	0.19	89.0
May	116,503	3,758	6,937	48.0	3.0	93.8	39.0	3.5	91.0	1.04	0.16	84.4
Jun	82,073	2,736	8,748	140.0	3.0	97.9	310.0	3.3	99.0	3.66	0.09	97.5
Jul	102,103	3,294	7,402	37.0	3.0	91.9	34.0	4.0	88.2	1.15	0.10	91.1
Aug	231,317	7,462	20,271	22.0	3.0	86.4	17.0	3.5	79.4	0.47	0.11	76.1
Sep	98,022	3,267	7,362	159.0	3.0	98.1	370.0	3.2	99.1	3.62	0.10	97.2
Oct	63,243	2,040	2,689	223.5	3.0	98.7	347.5	3.0	99.1	5.92	0.09	98.5
Nov	55,370	1,846	2,488	38.0	3.0	92.1	57.0	3.3	94.3	1.44	0.10	93.1
Dec	102,801	3,316	7,201	51.0	3.6	92.9	56.0	4.0	92.9	1.21	0.15	87.8
Total	1,391,607											
Average		3,798		82.7	3.8	92	154.0	4.3	94	2.33	0.13	90
Minimum												
Maximum			20,271									
Criteria		3,237			30			40			0.50	



Appendix A

		Ammonia		ТКМ				Nitrite		Nitrate			
MONTH	Average Raw Ammonia	Average Effluent Ammonia	Percent Removal	Average Raw TKN	Average Effluent TKN	Percent Removal	Average Raw Nitrite	Average Effluent Nitrite	Percent Removal	Average Raw Nitrate	Average Effluent Nitrate	Percent Removal	
	(mg/L)	(mg/L)	(%)	(mg/L)	(mg/L)	(%)	(mg/L)	(mg/L)	(%)	(mg/L)	(mg/L)	(%)	
Jan	n/a	5.75		33.00	7.50	77.3	n/a	0.05		n/a	1.1	n/a	
Feb	n/a	7.64		8.00	10.70	-33.8	n/a	0.08		n/a	0.6	n/a	
Mar	n/a	5.78		9.90	8.43	14.9	n/a	0.06		n/a	0.7	n/a	
Apr	n/a	6.38		9.80	7.68	21.6	n/a	0.05		n/a	0.4	n/a	
May	n/a	5.57		11.60	5.18	55.4	n/a	0.21		n/a	0.5	n/a	
Jun	n/a	0.28		23.20	1.23	94.7	n/a	0.13		n/a	0.4	n/a	
Jul	n/a	0.52		12.60	2.10	83.3	n/a	0.19		n/a	0.5	n/a	
Aug	n/a	0.67		4.90	1.98	59.7	n/a	0.06		n/a	0.2	n/a	
Sep	n/a	0.62		17.80	1.34	92.5	n/a	0.07		n/a	0.3	n/a	
Oct	n/a	0.66		38.10	1.45	96.2	n/a	0.05		n/a	0.4	n/a	
Nov	n/a	2.34		20.80	3.13	85.0	n/a	0.10		n/a	0.6	n/a	
Dec	n/a	7.15		19.00	8.30	56.3	n/a	0.05		n/a	0.8	n/a	
Total													
Average		3.61		17.39	4.92	59		0.09			0.52		
Minimum													
Maximum													
Criteria													



Appendix A

NORTH GLENGARRY WATER WORKS WASTEWATER TREATMENT PERFORMANCE RESULTS

2024

	Нус	Irogen Sulph	nide		E. coli			рН		Temp	Cl ₂
MONTH	Average Raw H ₂ S	Average Effluent H ₂ S	Percent Removal	Average Raw E. coli	Average Effluent E. coli	Percent Removal	Minimum Effluent pH	Average Effluent pH	Maximum Effluent pH	Average Effluent Temp	Average Effluent Cl ₂
	(mg/L)	(mg/L)	(%)	(cts/100ml)	(cts/100ml)	(%)				(°C)	(mg/L)
Jan	n/a	n/a		n/a	1.00		7.18	7.50	8.07	3.53	0.00
Feb	n/a	n/a		n/a	1.00		7.29	7.60	8.22	6.48	0.00
Mar	n/a	n/a		n/a	7.01		7.99	8.09	8.20	5.45	0.00
Apr	n/a	n/a		n/a	1.00		6.93	7.89	8.32	10.43	0.00
May	n/a	n/a		n/a	1.00		7.41	7.63	7.88	19.53	0.00
Jun	n/a	n/a		n/a	1.41		7.38	8.54	9.06	20.95	0.00
Jul	n/a	n/a		n/a	1.70		7.49	7.75	8.07	21.17	0.00
Aug	n/a	n/a		n/a	1.19		7.46	7.55	7.66	22.63	0.00
Sep	n/a	n/a		n/a	1.00		6.23	7.44	8.87	20.00	0.00
Oct	n/a	n/a		n/a	1.00		7.10	7.70	8.54	12.22	0.00
Nov	n/a	n/a		n/a	1.00		7.44	7.58	7.75	7.65	0.00
Dec	n/a	n/a		n/a	1.00		7.19	7.60	8.00	3.56	0.00
Total											
Average					1.3			7.62		13.06	0.00
Minimum							6.23				
Maximum					7.0				8.68	26.80	0.00
Criteria					200		6.0	6.5 - 8.5	9.5		0.02

NORTH GLENGARRY WATER WORKS

WASTEWATER TREATMENT WORKS PERFORMANCE RESULTS

Municipality: North Glengarry

Year: 2023

Project: Alexandria STP

Receiving Stream: Delisle River

Description: 1 Pumping Station, 1 Aerated Cell, 3 Facultative Cells

Design Capacity: 3237 m³/day

Continuous Discharge with Phosphorous Removal

		Flows		Bioche	mical O ₂ D	emand	Sus	pended Sc	olids	F	hosphoru	s
MONTH	Total Flows	Average Daily Flow	Maximum Daily Flow	Average Raw CBOD₅	Average Effluent CBOD₅	Percent Removal	Average Raw SS	Average Effluent SS	Percent Removal	Average Raw TP	Average Effluent TP	Percent Removal
	(m³)	(m³)	(m ³)	(mg/L)	(mg/L)	(%)	(mg/L)	(mg/L)	(%)	(mg/L)	(mg/L)	(%)
Jan	174,545	5,630	18,817	84.0	3.2	96.2	130.0	4.6	96.5	1.73	0.15	91.2
Feb	121,512	4,340	8,471	42.0	3.8	91.1	20.0	6.3	68.8	0.65	0.20	68.8
Mar	172,704	5,571	9,918	125.0	3.8	97.0	128.0	7.5	94.1	2.96	0.26	91.1
Apr	262,673	8,756	15,285	116.0	4.8	95.9	220.0	12.0	94.5	2.21	0.17	92.5
Мау	175,841	5,672	19,897	85.0	3.0	96.5	230.0	3.6	98.4	2.50	0.10	95.8
Jun	64,535	2,151	2,728	34.0	6.5	80.9	82.0	7.0	91.5	1.48	0.10	93.1
Jul	76,195	2,458	4,815	139.0	3.0	97.8	380.0	3.5	99.1	4.66	0.11	97.6
Aug	75,598	2,439	3,451	134.0	3.0	97.8	292.0	4.2	98.6	4.31	0.06	98.6
Sep	52,024	1,734	2,277	61.0	4.0	93.4	98.0	5.0	94.9	1.66	0.05	97.3
Oct	67,387	2,174	3,578	52.0	3.0	94.2	250.0	3.8	98.5	2.88	0.10	96.4
Nov	76,542	2,551	3,475	173.0	3.8	97.8	590.0	4.0	99.3	6.70	0.16	97.7
Dec	161,293	5,203	13,039	35.0	3.8	89.3	86.0	11.0	87.2	0.60	0.20	67.1
Total	1,480,848											
Average		4,057		90.0	3.8	94	208.8	6.0	93	2.70	0.14	91
Maximum			19,897	173	6.5	98	590.0	12.0	99	6.70	0.26	99
Criteria		3,237			30			40			0.50	



2023

		Ammonia			TKN			Nitrite			Nitrate	
MONTH	Average Raw Ammonia	Average Effluent Ammonia	Percent Removal	Average Raw TKN	Average Effluent TKN	Percent Removal	Average Raw Nitrite	Average Effluent Nitrite	Percent Removal	Average Raw Nitrate	Average Effluent Nitrate	Percent Removal
	(mg/L)	(mg/L)	(%)	(mg/L)	(mg/L)	(%)	(mg/L)	(mg/L)	(%)	(mg/L)	(mg/L)	(%)
Jan	n/a	5.79		10.00	7.96	20.4	n/a	0.11		n/a	0.8	
Feb	n/a	7.49		8.90	8.10	9.0	n/a	0.06		n/a	0.1	
Mar	n/a	7.49		17.50	13.08	25.3	n/a	0.05		n/a	0.1	
Apr	n/a	2.73		10.60	4.50	57.5	n/a	0.06		n/a	1.0	
Мау	n/a	0.17		13.80	1.14	91.7	n/a	0.05		n/a	0.4	
Jun	n/a	0.23		20.60	1.20	94.2	n/a	0.06		n/a	0.4	
Jul	n/a	0.38		24.90	1.75	93.0	n/a	0.06		n/a	0.3	
Aug	n/a	0.21		22.80	1.34	94.1	n/a	0.05		n/a	0.5	
Sep	n/a	0.07		19.40	1.03	94.7	n/a	0.08		n/a	0.1	
Oct	n/a	1.92		18.40	3.00	83.7	n/a	0.06		n/a	0.1	
Nov	n/a	4.57		29.40	6.80	76.9	n/a	0.06		n/a	0.5	
Dec	n/a	4.79		7.00	8.25	-17.9	n/a	0.05		n/a	0.9	
Total												
Average		2.99		16.94	4.85	60		0.06			0.43	
Maximum		7.49		29.4	13.08	95		0.11			1.01	
Criteria												

	Hydrogen Sulphide				E. coli			рН		Temp	Cl ₂
MONTH	Average Raw H ₂ S	Average Effluent H ₂ S	Percent Removal	Average Raw E.coli	Average Effluent E.coli	Percent Removal	Minimum Effluent pH	Average Effluent pH	Maximum Effluent pH	Average Effluent Temp	Average Effluent Cl ₂
	(mg/L)	(mg/L)	(%)	(cts/100ml)	(cts/100ml)	(%)				(°C)	(mg/L)
Jan	n/a	0.01		n/a	5.83		7.00	8.07	7.31	4.18	0.00
Feb	n/a	0.00		n/a	1.90		7.05	7.89	7.46	5.10	0.00
Mar	n/a	0.00		n/a	5.61		6.95	8.67	7.59	3.75	0.00
Apr	n/a	0.00		n/a	8.85		7.68	8.32	7.94	8.88	0.00
Мау	n/a	0.00		n/a	1.32		7.45	8.27	7.94	14.02	0.00
Jun	n/a	0.00		n/a	1.00		7.30	8.31	7.97	20.70	0.00
Jul	n/a	0.00		n/a	1.19		7.30	8.64	7.92	23.88	0.00
Aug	n/a	0.00		n/a	1.00		7.01	8.20	7.53	20.76	0.00
Sep	n/a	0.00		n/a	1.00		7.00	7.61	7.36	20.03	0.00
Oct	n/a	0.00		n/a	1.82		7.18	7.92	7.51	12.12	0.00
Nov	n/a	0.00		n/a	1.19		7.53	7.91	7.71	5.28	0.00
Dec	n/a	0.00		n/a	1.68		7.00	8.63	7.81	6.23	0.00
Total											
Average		0.00			2.0		7.62	7.62	7.62	13.06	0.00
Maximum		0.01			8.9		8.68	8.68	8.68	26.80	0.00
Criteria					200		6.0	6.5 - 8.5	9.5		0.02



Appendix A

NORTH GLENGARRY WATER WORKS

WASTEWATER TREATMENT WORKS PERFORMANCE RESULTS

Municipality:	North Glengarry	Year:	2022
Project:	Alexandria STP	Receiving Stream:	Delisle River
Description:	1 Pumping Station, 1 Aerated Cell, 3 Facultative Cells	Design Capacity:	3237 m³/day
	Continuous Discharge with Phosphorous Removal		

Biochemical O2 Demand Suspended Solids Phosphorus Flows Average Average Average Average Maximum Average Total Average Percent Percent Average Percent MONTH Effluent Effluent Effluent Raw Raw TP Flows **Daily Flow Daily Flow** Removal Raw SS Removal Removal TP CBOD₅ CBOD₅ SS Jan 62,453 2,015 2,495 127.0 6.8 94.7 160.0 4.8 97.0 1.74 0.23 86.9 Feb 72,709 2,597 5,169 165.0 5.0 97.0 560.0 10.0 98.2 4.91 0.32 93.5 Mar 187,946 6,063 14,509 101.0 3.7 96.4 335.0 6.7 98.0 0.48 0.25 48.6 Apr 187,526 6,251 16,656 3.3 94.2 87.2 0.26 80.3 56.0 96.0 12.3 1.31 4.0 May 105.742 3.411 6,904 44.0 90.9 85.0 7.5 91.2 1.50 0.17 88.8 77,861 2,595 3,334 3.0 4.23 Jun 141.0 97.9 390.0 4.4 98.9 0.10 97.5 2,761 Jul 61,580 1,986 163.0 3.0 98.2 465.0 4.0 99.1 4.38 0.12 97.3 3.0 Aug 70.245 2.266 3.926 188.0 98.4 560.0 6.2 98.9 5.83 0.21 96.4 Sep 78.388 2.613 4.251 37.0 3.0 91.9 48.0 4.5 90.6 1.20 0.12 90.0 3.0 325.0 5.0 Oct 66,719 2,152 2,521 139.0 97.8 98.5 3.63 0.11 97.0 3.2 97.3 Nov 75,197 2,507 5,904 3.0 -6.7 400.0 5.2 98.7 4.53 0.12 Dec 116,444 3,756 17,077 129.0 3.3 97.5 250.0 5.0 98.0 3.56 96.9 0.11 Total 1,162,810 Average 3,184 107.8 3.7 87 306.2 6.3 96 3.11 0.18 89 Minimum Maximum 17,077 188 6.8 98 560.0 12.3 99 5.83 0.32 98 Criteria 3,237 30 40 0.50

		Ammonia		TKN				Nitrite		Nitrate			
MONTH	Average Raw Ammonia	Average Effluent Ammonia	Percent Removal	Average Raw TKN	Average Effluent TKN	Percent Removal	Average Raw Nitrite	Average Effluent Nitrite	Percent Removal	Average Raw Nitrate	Average Effluent Nitrate	Percent Removal	
	(mg/L)	(mg/L)	(%)	(mg/L)	(mg/L)	(%)	(mg/L)	(mg/L)	(%)	(mg/L)	(mg/L)	(%)	
Jan	n/a	9.31		17.30	17.18	0.7	n/a	0.10		n/a	0.3		
Feb	n/a	12.23		27.80	15.46	44.4	n/a	0.10		n/a	0.1		
Mar	n/a	10.39		13.70	13.82	-0.9	n/a	0.10		n/a	0.1		
Apr	n/a	4.25		9.90	7.53	24.0	n/a	0.10		n/a	0.8		
Мау	n/a	2.21		14.40	3.88	73.1	n/a	0.90		n/a	0.4		
Jun	n/a	0.60		22.30	1.74	92.2	n/a	0.10		n/a	0.3		
Jul	n/a	0.18		24.60	1.58	93.6	n/a	0.10		n/a	0.1		
Aug	n/a	0.41		30.90	2.40	92.2	n/a	0.10		n/a	0.1		
Sep	n/a	1.73		21.00	2.30	89.0	n/a	0.10		n/a	0.2		
Oct	n/a	1.09		21.30	2.28	89.3	n/a	0.10		n/a	0.3		
Nov	n/a	1.58		26.70	3.22	87.9	n/a	0.10		n/a	0.4		
Dec	n/a	3.94		19.20	6.15	68.0	n/a	0.08		n/a	0.7		
Total													
Average		3.99		20.76	6.46	62.8		0.16			0.32		
Minimum													
Maximum		12.23		30.90	17.18	93.6		0.90			0.80		
Criteria													

	Hydrogen	Sulphide			E. coli			рН		Temp	Cl ₂
MONTH	Average Raw H ₂ S	Average Effluent H ₂ S	Percent Removal	Average Raw E.coli	Average Effluent E.coli	Percent Removal	Minimum Effluent pH	Average Effluent pH	Maximum Effluent pH	Average Effluent Temp	Average Effluent Cl ₂
	(mg/L)	(mg/L)	(%)	(cts/100ml)	(cts/100ml)	(%)				(°C)	(mg/L)
Jan	n/a	0.05		n/a	5.28		7.20	7.87	8.94	7.33	0.00
Feb	n/a	n/a		n/a	2.14		7.02	7.36	7.67	3.80	0.00
Mar	n/a	n/a		n/a	5.57		7.08	7.40	7.70	4.69	0.00
Apr	n/a	n/a		n/a	6.62		7.29	8.01	8.57	7.60	0.00
Мау	n/a	n/a		n/a	3.56		7.39	7.98	8.72	16.05	0.00
Jun	n/a	n/a		n/a	1.32		7.43	7.68	8.40	20.36	0.00
Jul	n/a	n/a		n/a	1.00		7.35	7.63	8.24	23.18	0.00
Aug	n/a	n/a		n/a	1.00		7.35	7.43	7.55	22.92	0.00
Sep	n/a	n/a		n/a	1.78		7.24	7.63	7.84	17.88	0.00
Oct	n/a	n/a		n/a	1.00		7.20	7.68	8.16	11.63	0.00
Nov	n/a	n/a		n/a	1.00		7.49	7.76	8.25	7.42	0.00
Dec	n/a	n/a		n/a	1.00		7.33	7.66	7.90	3.08	0.00
Total											
Average		0.05			2.0			7.62		13.06	0.00
Minimum							7.02				
Maximum		0.05			6.6				8.68	26.80	0.00
Criteria					200		6.0		9.5		0.02